

Emission Test Certificate

Thursday July 7th, 2010

Supplier: T & R Interior Systems Limited (PO Box 38533, Wellington Mail Centre, 5045, Wellington. 12 Glover St, Ngauranga, Wellington 6035)

Sample Description: Harmony "C-MAX" High Performance Glass Wool Acoustic Ceiling Tile

Date Tested: June 2010

Test Method: GREENGUARD Certification Program for Low Emitting Products incorporating ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

GREENGUARD Certification Program Emission Criteria for Ceiling Systems	Harmony "C-MAX" High Performance Glass Wool Acoustic Ceiling Tile
Formaldehyde $\leq 0.06 \text{ mg/m}^3$	0.05 mg/m^3
Total Volatile Organic Compounds $\leq 0.5 \text{ mg/m}^3$	0.004 mg/m^3 Individual VOCs were all less than their Threshold Limit Values. Carcinogens and reproductive toxins were not identified as part of the VOCs.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Project CV100526