

Emission Test Certificate

Friday 23rd April 2021

Supplier: Sabre Adhesives

Sample Description: Sabregrip S42 Coated on SS Sheet

Date Tested: July 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116: 2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

<p align="center">Green Building Council of Australia Green Star Design & As Built v1.1 - 13.1.2B & 13.2 Green Star Interiors V1.1 - 12.1.2B</p>	<p align="center">Sabregrip S42 Coated on SS Sheet</p>
<p align="center">Total Volatile Organic Compound Emission Rate Limit: ≤0.500 mg/m²/hr</p>	<p align="center">Total Volatile Organic Compound Emission Rate: 0.124 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Luke Morley
BSc (Technology)
Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

V2104061