



CERTIFICATE OF TEST

Report No. 32083/1
Page 1 of 1 page
Reissue 1

Reference: T & R INTERIOR SYSTEMS LTD.
Order No. 694669
Attention: Colin Eyre

Tension & Compression Testing of Steel Ceiling Supports

Product Tested: Cross Tee/Main Connection – Grid CBI
T & R Two-way suspended ceiling systems

Test Equipment: Shimadzu Universal Grade 1 Testing Machine, Model No. REH50, Serial No. 72666. Calibration due May 2011.
Precision 500Kg, Serial No. 212636. Calibration due May 2011.

RESULTS:

| Item | Tension Test Load | | Compression Test Load | |
|-------------|-------------------|------------|-----------------------|-----------|
| | (N) | (Kg) | (N) | (Kg) |
| 1 | 1280 | 131 | 952 | 98 |
| 2 | 1306 | 133 | 890 | 91 |
| 3 | 1219 | 124 | 872 | 89 |
| 4 | 1203 | 123 | 849 | 87 |
| 5 | 1320 | 135 | 842 | 86 |
| 6 | 1360 | 139 | 828 | 84 |
| 7 | 1280 | 131 | 850 | 87 |
| 8 | 843 | 86 | 802 | 82 |
| 9 | 1355 | 138 | 950 | 97 |
| 10 | 1220 | 124 | 900 | 92 |
| Mean | 1239 | 126 | 875 | 89 |

Tested by: AG
Date tested: 28/03/11
Reported by: AG
Date reported: 28/03/11
Checked by: CHT

Approved Signatory:
A. GHERMAN

Reissue 1 issued to correct the product description from "C8i" to "CBI"
Date of reissue: 06/04/11



All tests reported herein have been performed in accordance with the Laboratory's scope of accreditation